

WASATCH COUNTY FIRE DISTRICT

25 North Main Street, Heber City, UT 435-940-9636

FIRE SAFETY INSPECTION REPORT

Business Name: _____ Inspection Date: _____

Business Address: _____ Suite: _____ Business Phone: _____

No.	Violations	No.	Locations/Remarks	Cleared
ACCESS				
1	Maintain fire lane free of obstructions			/ /
2	Provide address numbering which is visible from street			/ /
3	Provide Lock box for fire dept. access			
EXITING				
4	Remove obstructions at exits, doors, aisles, corridors, stairways, etc.			/ /
5	Exit door to open without a key or any special knowledge or effort			
6	Provide sign over main exit door			/ /
7	Repair non-operable exit door hardware			/ /
8	Removed obstructions from door required to be closed			
9	Remove locks & latches from doors with panic hardware			/ /
10	Remove storage from under unprotected stairway			
11	Provide/maintain exit sign/emergency lighting			/ /
FIRE EXTINGUISHERS				
12	Have fire extinguisher serviced and tagged			/ /
13	Provide/mount fire extinguisher as indicated			
14	Provide clear access to fire extinguisher			/ /
15	Post a sign indicating fire extinguisher location			
16	Maintain 3 foot clearance for access/use of fire appliances/equipment			/ /
FIRE PROTECTION SYSTEMS				
17	Secure all system control valves in the open position			
18	Replace damaged, corroded or painted sprinkler heads/ Fire department connection (FDC) caps			
19	Provide annual certification for sprinkler/standpipe system	Re-inspection dates		Inspector
20	Provide sprinkler coverage in unprotected areas	1 st	/ /	
21	Provide spare sprinkler heads and/or compatible wrench			
22	Hood and duct extinguishing system to be serviced and tagged	2 nd	/ /	
23	Remove grease from hood, duct, and filters (keep clean)			
FIRE ALARM SYSTEMS				
24	Maintain, repair, inspect, and/or test fire alarm system	Refer to FPB		/ /
FIRE SEPARATIONS				
25	Repair holes in required fire resistive construction	3 rd	/ /	
26	Provide/repair self or automatic closing fire rated assemblies	Hearing	/ /	
ELECTRICAL				
27	Discontinue use of extension cords	District attorney	/ /	
28	Install permanent wiring for fixed or stationary appliance			
29	Provide cover plates for all junction boxes	Final clearance	/ /	
30	Remove exposed wiring or protect in approved conduit			
31	Provide a clear work space at all electrical panels (30" in width, 36" in depth and 78" in height)			
32	Maintain wiring in good condition & protect from damage			
FLAMMABLE LIQUIDS – COMPRESSED GASES				
33	Provide flammable liquid storage cabinet or reduce storage	<p>You are hereby notified to correct all violations immediately or show cause why you should not be required to re-inspection will be conducted after _____ days from the date of this notice. Willful failure to comply with this notice is a misdemeanor. Violations which are not corrected immediately and or remain after the re-inspection may be processed as a criminal offense. Thank you for your assistance and cooperation in minimizing the fire and life loss in your community.</p> <p style="text-align: center;">BY ORDER OF THE FIRE CHIEF</p> <p>SIGNATURE OF RECIPIENT: _____ ___Owner ___ manager ___ employee ___ other</p>		
34	Remove all fueled vehicles or equipment from buildings			
35	Secure compressed gas cylinders & identify product name			
STORAGE – HOUSEKEEPING				
36	Arrange storage in an orderly manner to provide access/egress			
37	Remove combustible storage from boiler, mechanical, or electrical rooms			
38	Reduce storage to 24 " below ceiling or 18" from sprinkler heads			
39	Provide approved metal container from oily rag storage			
40	Remove waste & rubbish material from the premises daily			
41	Keep dumpster 5 ' away from buildings			
42	Miscellaneous combustible material storage inside and outside			
MISCELLANEOUS				
43	Other violations and comments			
NO VIOLATIONS NOTED THIS DATE – THANK YOU FOR BEING SAFE		Inspecting Officer: _____ FPB _____ COMPANY _____ Shift _____ Page _____ of _____		