

MAINTAIN WIRING IN GOOD CONDITION AND PROTECT FROM DAMAGE

CODE SECTIONS

International Fire Code 2003 Edition

605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified hazardous electrical condition in permanent wiring shall be brought to the attention of the code official responsible for enforcement of the *ICC Electrical Code*. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.

EXPLANATION

All electrical wiring shall be installed, maintained in good condition, and protected from damage in accordance with the Electrical Code. Any frayed wires, undersized wires, and illegally or im properly installed wiring shall be corrected. Questions and clarifications can be addressed to the Wasatch County Building Inspection Division for correction.

RATIONALE

Improperly installed, poorly maintained, and damaged wires pose a significant fire risk to your building. Electrical systems must be installed and maintained per the Electrical Code to minimize fire potential in your building.